



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

PAT MCCRORY
GOVERNOR

ANTHONY J. TATA
SECRETARY

September 23, 2013

ADDENDUM #3

To: Plan Holders

From: Wanda H. Austin, PE
Proposals Engineer

RE:
Contract ID: DN00296
County: Graham
Letting Date: September 24, 2013

The following questions have been asked regarding the above project. Answers are provided in italics.

1. Will the contractor be required to install a portable concrete type barrier once the guardrail is removed? How is this to be addressed with the NCDOT not wanting to close the road during the whole contract time? *The Department does not feel that concrete barrier will need to be used, however, if during the construction phasing safety becomes compromised we will make adjustments then as necessary.*
2. Could a temporary red light system be used instead of flaggers during and after work hours? *Yes, we are open to the use of portable traffic signals; however, no separate pay item will be added. The cost of the system will need to be incidental to other pay items in the contract.*
3. Is a fence required to go on top of the finished wall? One of the notes on the retaining wall plans say a fence is required to see roadway plans for attachment details. I don't see anything on the roadway plan other than the guardrail. Can you confirm a fence is required and if so can you provide details? *The fence will not be required.*

Please insert this letter into the addendum section of the proposal and sign the verification. Thank you for your attention to this matter.

Fourteenth Division Office

Phone: (828)586-2141

253 Webster Road, Sylva, North Carolina 28779

Fax: (828)586-4043